

**Zavod Logicroof LTD**  
**Vostochniy promuzel 21**  
**390047 Ryazan**  
**RUSSIA**

Your ref.  
Mr. Ildus Nagaev

Your e-mail address  
nagaev@tn.ru

E-mail address our ref.  
bente.w.oftes@sintef.no

Project No. / Ref. to Report no  
102008571-1. / -

Date  
2019-03-18

## ANNUAL CONTROL 2018

SINTEF Building and Infrastructure (SINTEF), Trondheim, has according to contract 102008571-1 concerning SINTEF Technical Approvals, see Table 1, carried out annual surveillance control.

Table 1. Approvals belonging to contract 102008571-1

Approval No	Products
20495	LOGICROOF V-RP 1.2/1.5/1.8/2.0
20495	LOGICROOF V-SR 1.5/1.8/2.0

In Table 2, 3 and 4 a summary of performed controls for this year is listed.

Table 2. Inspection performed at the manufacturer

Inspection carried out by	Inspection OK?	Comments
ITC	Yes	

Table 3. Control testing of random product samples

Product Name	Thickness (mm)	Control testing performed by	Test results ok?	Comments
LOGICROOF V-RP	1.2	Kiwa BDA Testing B.V.	Yes	Resistance to impact (EN 12691, A) did not pass the control limit, 600 mm. Control limit for resistance to impact has been lowered to 500 mm. Some other properties has also been given lower limits according to customer's wish and in accordance with updated DoP.


Table 4. Control testing of fire properties

Approval no	Product Name	Fire testing performed by	Tested on a substrate of	Fire properties ok?	Comments
20495	LOGICROOF V-RP 1.2	Eurofins Expert Services Oy	EPS+glass fleece Mineral wool	Yes Yes	

SINTEF confirms Approval no. 20495 belonging to contract 102008571-1 can be valid again.  
Required reports/documentation have been received with satisfying results and content.

Yours sincerely,

For SINTEF Building and Infrastructure



Bente W. Ofte  
Project manager



Jan Ove Busklein  
Quality Assurance